

Annual CCR Surface Impoundment PE Inspection

Pond 003
New Madrid Power Plant
New Madrid, MO

Associated Electric Cooperative, Inc.

Inspection

Visual Inspection

On July 15, 2022, a visual inspection of the surface impoundment was completed. The visual inspection included both a visual inspection of the CCR impoundment to identify signs of distress or malfunction and a visual inspection of the hydraulic structures for structural integrity. The following subsections and enclosed inspection report describe the conditions observed during the inspection.

Changes in Geometry

There have been no changes to the geometry of the impounding structure since the previous annual inspection.

Instrumentation Readings

Piezometers/monitoring wells are located along the crest of the dikes of Pond 003. The piezometers/groundwater monitoring wells were installed for purposes of monitoring groundwater and are not monitored for structural stability purposes. No readings were taken. No other instrumentation was identified as part of the inspection.

Impounded Water Depth

On the inspection date, the pond water elevation was recorded at 298.8 ft. The concrete stop logs in the decant structure have been set at an approximate elevation of 298 ft. and have not been adjusted.

Storage Capacity

The remaining storage capacity of the impoundment was approximated to be 167 acre-ft. As part of normal operation, ash collected in the pond is periodically disposed of in the Utility Waste Landfill and a very minimal amount of ash accumulates in the pond.

Volumes

The impounded water is approximated to be 48 acre-ft. The impounded CCR volume was approximated to be 1768 acre-ft. As part of normal operation, ash collected in the pond is periodically disposed of in the Utility Waste Landfill and a very minimal amount of ash accumulates in the pond.

Inspection for Structural Weaknesses

The impoundment was visually inspected for any appearances of an actual or potential structural weakness of the CCR unit. The visual inspection did not indicate any deficiencies. Details of this inspection can be found in the enclosed inspection checklist.

Certification

The assessment of the general condition of the surface impoundment is based upon available data and visual observation as required by 40 CFR 257.83 (b) – Inspection Requirements for CCR Surface Impoundments. In reviewing this report, it should be realized that the described condition of the surface impoundment is based on observations of field conditions at the time of inspection. Conditions of surface impoundments depend on numerous internal and external conditions; therefore, it should be noted that the estimates and observations only represent the conditions at the time of inspection.

Signed: Lowell Dennis Cox

Print Name: Lowell Dennis Cox

Missouri License Number: E2001004579

Date: 7/15/2022



Lowell Dennis Cox
7/15/2022

Dam/Impoundment Evaluation Summary Detail Sheet

1. NID ID: N/A		4. Inspection Date: July 15, 2022	
2. Dam Name: Pond 003		5. Last Insp. Date: July 19, 2021	
3. Dam Location: 41 St. Jude Park, Marston, MO		6. Next Inspection:	
7. Inspector: Dennis Cox, P. E.			
8. Consultant: N/A			
9. Hazard Code:		9a. Is Hazard Code Change Requested?:	
10. Insp. Frequency: #N/A		11. Overall Physical Condition of Dam:	
12. Spillway Capacity (% SDF)			
E1. Design Methodology: 4		E7. Low-Level Discharge Capacity: 4	
E2. Level of Maintenance: 4		E8. Low-Level Outlet Physical Condition: 4	
E3. Emergency Action Plan: 5		E9. Spillway Design Flood Capacity: N/A	
E4. Embankment Seepage: 5		E10. Overall Physical Condition of the Dam: 5	
E5. Embankment Condition: 5		E11. Estimated Repair Cost: N/A	
E6. Concrete Condition: 5			

Evaluation Description

E1: DESIGN METHODOLOGY

1. Unknown Design – no design records available
2. No design or post-design analyses
3. No analyses, but dam features appear suitable
4. Design or post design analysis show dam meets most criteria
5. State of the art design – design records available & dam meets all criteria

E2: LEVEL OF MAINTENANCE

1. Dam in disrepair, no evidence of maintenance, no O&M manual
2. Dam in poor level of upkeep, very little maintenance, no O&M manual
3. Dam in fair level of upkeep, some maintenance and standard procedures
4. Adequate level of maintenance and standard procedures
5. Dam well maintained, detailed maintenance plan that is executed

E3: EMERGENCY ACTION PLAN

1. No plan or idea of what to do in the event of an emergency
2. Some idea but no written plan
3. No formal plan but well thought out
4. Available written plan that needs updating
5. Detailed, updated written plan available and filed with MADCR, annual training

E4: SEEPAGE (Embankments, Foundations, & Abutments)

1. Severe piping and/or seepage with no monitoring
2. Evidence of monitored piping and seepage
3. No piping but uncontrolled seepage
4. Minor seepage or high volumes of seepage with filtered collection
5. No seepage or minor seepage with filtered collection

E5: EMBANKMENT CONDITION

1. Severe erosion and/or large trees
2. Significant erosion or significant woody vegetation
3. Brush and exposed embankment soils, or moderate erosion
4. Unmaintained grass, rodent activity and maintainable erosion
5. Well maintained healthy uniform grass cover

E6: CONCRETE CONDITION

1. Major cracks, misalignment, discontinuities causing leaks, seepage or stability concerns
2. Cracks with misalignment inclusive of transverse cracks with no misalignment but with potential for significant structural degradation
3. Significant longitudinal cracking and minor transverse cracking
4. Spalling and minor surface cracking
5. No apparent deficiencies

E7: LOW-LEVEL OUTLET DISCHARGE CAPACITY

1. No low level outlet, no provisions (e.g. pumps, siphons) for emptying pond
2. No operable outlet, plans for emptying pond, but no equipment
3. Outlet with insufficient drawdown capacity, pumping equipment available
4. Operable gate with sufficient drawdown capacity
5. Operable gate with capacity greater than necessary

E8: LOW-LEVEL OUTLET PHYSICAL CONDITION

1. Outlet inoperative needs replacement, non-existent or inaccessible
2. Outlet inoperative needs repair
3. Outlet operable but needs repair
4. Outlet operable but needs maintenance
5. Outlet and operator operable and well maintained

E9: SPILLWAY DESIGN FLOOD CAPACITY

1. 0 - 50% of the SDF or unknown
2. 50-90% of the SDF
3. 90 - 100% of the SDF
4. >100% of the SDF with actions required by caretaker (e.g. open outlet)
5. >100% of the SDF with no actions required by caretaker

E10: OVERALL PHYSICAL CONDITION OF DAM

1. UNSAFE – Major structural, operational, and maintenance deficiencies exist under normal operating conditions
2. POOR - Significant structural, operation and maintenance deficiencies are clearly recognized under normal loading conditions
3. FAIR - Significant operational and maintenance deficiencies, no structural deficiencies. Potential deficiencies exist under unusual loading conditions that may realistically occur. Can be used when uncertainties exist as to critical parameters
4. SATISFACTORY - Minor operational and maintenance deficiencies. Infrequent hydrologic events would probably result in deficiencies.
5. GOOD - No existing or potential deficiencies recognized. Safe performance is expected under all loading including SDF

E11: ESTIMATED REPAIR COST

Estimation of the total cost to address all identified structural, operational, maintenance deficiencies. Cost shall be developed utilizing standard estimating guides and procedures

Changes/Deviations to Database Information since Last Inspection

DAM SAFETY INSPECTION CHECKLIST

NAME OF DAM: <u>Pond 003</u>	STATE ID #: <u>MO-0001171</u>
REGISTERED: (YES/NO) <u>No</u>	NID ID #: <u>N/A</u>
STATE SIZE CLASSIFICATION: <u>N/A</u>	STATE HAZARD CLASSIFICATION: <u>Significant</u>
	CHANGE IN HAZARD CLASSIFICATION REQUESTED?: (YES/NO) <u>No</u>

DAM LOCATION INFORMATION

CITY/TOWN: <u>New Madrid</u>	COUNTY/STATE: <u>New Madrid/Missouri</u>
DAM LOCATION: <u>41 St. Jude Park, Marston, MO</u> (street address if known)	ALTERNATE DAM NAME: <u>N/A</u>
USGS QUAD.: <u>New Madrid, MO-KY</u>	LAT.: <u>36° 30.4' 28"</u> LONG.: <u>89° 33' 27"</u>
DRAINAGE BASIN: <u>N/A</u>	RIVER: <u>Mississippi River</u>
IMPOUNDMENT NAME(S): <u>Unlined Ash Pond (003 Pond)</u>	

GENERAL DAM INFORMATION

TYPE OF DAM: <u>Earthen Incised and Bermed</u>	OVERALL LENGTH (FT): <u>9300</u>
PURPOSE OF DAM: <u>Sedimentation and Storage Basin</u>	NORMAL POOL STORAGE (ACRE-FT): _____
YEAR BUILT: <u>1972</u>	MAXIMUM POOL STORAGE (ACRE-FT): <u>1707</u>
STRUCTURAL HEIGHT (FT): <u>20</u>	EL. NORMAL POOL (FT): <u>298.9</u>
HYDRAULIC HEIGHT (FT): <u>8</u>	EL. MAXIMUM POOL (FT): <u>307.0 (minimum crest elevation)</u>
RESERVOIR SURFACE AREA (ACRES): <u>110</u>	WINTER DRAWDOWN (FT BELOW NORMAL POOL) <u>0.0</u>
PUBLIC ROAD ON CREST: <u>No</u>	DRAWDOWN VOL. (AC-FT) <u>0.0</u>
PUBLIC BRIDGE OVER SPILLWAY: <u>No</u>	

NAME OF DAM: Pond 003

STATE ID #: MO-0001171

INSPECTION DATE: July 15th, 2022

NID ID #: N/A

INSPECTION SUMMARY

DATE OF INSPECTION: July 17th,

DATE OF PREVIOUS INSPECTION: July 19th, 2021

TEMPERATURE/WEATHER: 84 Degrees, Sunny

ARMY CORPS PHASE I:
(YES/NO)

If YES, date _____

CONSULTANT: N/A

PREVIOUS ALT. PHASE I:
(YES/NO)

If YES, date _____

BENCHMARK/DATUM: NAVD88

OVERALL PHYSICAL
CONDITION OF DAM: _____

DATE OF LAST REHABILITATION: N/A

SPILLWAY CAPACITY: _____

EL. POOL DURING INSP.: 298.8

EL. TAILWATER DURING INSP.: 285

PERSONS PRESENT AT INSPECTION

NAME
Dennis Cox

TITLE/POSITION
Supervisor - Coal Plant Eng

REPRESENTING
AECI

NAME OF DAM: Pond 003

STATE ID #: MO-0001171

INSPECTION DATE: July 15th, 2022

NID ID #: N/A

OWNER: ORGANIZATION Associated Electric Cooperative, Inc
NAME/TITLE Dennis Cox - Supervisor Plant En
STREET P.O. Box 156
TOWN, STATE, ZIP New Madrid, MO 63869
PHONE _____
EMERGENCY PH. # _____
FAX _____
EMAIL _____
OWNER TYPE Private

CARETAKER: ORGANIZATION Associated Electric Cooperative, Inc.
NAME/TITLE Dennis Cox - Supervisor Plant Eng.
STREET P.O. Box 156
TOWN, STATE, ZIP New Madrid, MO 63869
PHONE _____
EMERGENCY PH. # _____
FAX _____
EMAIL _____

PRIMARY SPILLWAY TYPE Decant Structure

SPILLWAY LENGTH (FT) N/A

SPILLWAY CAPACITY (CFS) N/A

AUXILIARY SPILLWAY TYPE N/A

AUX. SPILLWAY CAPACITY (CFS) N/A

NUMBER OF OUTLETS One

OUTLET(S) CAPACITY (CFS) Unknown

TYPE OF OUTLETS One Decant

TOTAL DISCHARGE CAPACITY (CFS) Unknown

DRAINAGE AREA (SQ MI) 0.17

SPILLWAY DESIGN FLOOD (PERIOD/CFS) Unknown

HAS DAM BEEN BREACHED OR
OVERTOPPED? (YES/NO): No

IF YES, PROVIDE DATE(S) _____

FISH LADDER (LIST TYPE IF PRESENT) Unknown

DOES CREST SUPPORT
PUBLIC ROAD? (YES/NO) No

IF YES, ROAD NAME: _____

PUBLIC BRIDGE WITHIN 50'
OF DAM? (YES/NO): No

IF YES, ROAD/BRIDGE NAME: _____
MHD BRIDGE NO. (IF APPLICABLE) _____

NAME OF DAM: Pond 003

STATE ID #: MO-0001171

INSPECTION DATE: July 15th, 2022

NID ID #: N/A

EMBANKMENT (CREST)

AREA INSPECTED	CONDITION	OBSERVATIONS	NO	MONITOR	REPAIR
			ACTION		
CREST	1. SURFACE TYPE	Gravel access road, Western crest was paved levee road.	X		
	2. SURFACE CRACKING	None Observed	X		
	3. SINKHOLES, ANIMAL BURROWS	None Observed	X		
	4. VERTICAL ALIGNMENT (DEPRESSIONS)	None Observed	X		
	5. HORIZONTAL ALIGNMENT	Alignment has not shifted or moved	X		
	6. RUTS AND/OR PUDDLES	None Observed	X		
	7. VEGETATION (PRESENCE/CONDITION)	Crest of embankment is gravel	X		
	8. ABUTMENT CONTACT	N/A	X		

ADDITIONAL COMMENTS: _____

NAME OF DAM: Pond 003

STATE ID #: MO-0001171

INSPECTION DATE: July 15th, 2022

NID ID #: N/A

EMBANKMENT (D/S SLOPE)

AREA INSPECTED	CONDITION	OBSERVATIONS	NO ACTION	MONITOR	REPAIR
D/S SLOPE	1. WET AREAS (NO FLOW)				
	2. SEEPAGE	None Observed	X		
	3. SLIDE, SLOUGH, SCARP	None Observed	X		
	4. EMB.-ABUTMENT CONTACT	N/A			
	5. SINKHOLE/ANIMAL BURROWS	None Observed	X		
	6. EROSION	None Observed	X		
	7. UNUSUAL MOVEMENT	None Observed	X		
	8. VEGETATION (PRESENCE/CONDITION)	Areas of grassy vegetation in riprap at embankment toe			X

ADDITIONAL COMMENTS: Grassy vegetation in riprap will be trimmed and spraed with herbicide in the next 30 days.

NAME OF DAM: Pond 003

STATE ID #: MO-0001171

INSPECTION DATE: July 15th, 2022

NID ID #: N/A

EMBANKMENT (U/S SLOPE)

AREA INSPECTED	CONDITION	OBSERVATIONS	NO	MONITOR	REPAIR
			ACTION		
U/S SLOPE	1. SLIDE, SLOUGH, SCARP	None Observed	X		
	2. SLOPE PROTECTION TYPE AND COND.	Areas with riprap in Good condition	X		
	3. SINKHOLE/ANIMAL BURROWS	None Observed	X		
	4. EMB.-ABUTMENT CONTACT	None Observed	X		
	5. EROSION	None Observed	X		
	6. UNUSUAL MOVEMENT	None Observed	X		
	7. VEGETATION (PRESENCE/CONDITION)	Grassed. Areas of vegetation exceeding 6-in. on eastern embankment.			

ADDITIONAL COMMENTS: Ash has been stockpiled to an elevation equal to the embankment in the Northern portion of the ash pond.
Therefore, the upstream slope was covered in ash and not visible for inspection.

NAME OF DAM: Pond 003

STATE ID #: MO-0001171

INSPECTION DATE: July 15th, 2022

NID ID #: N/A

INSTRUMENTATION

AREA INSPECTED	CONDITION	OBSERVATIONS	NO ACTION	MONITOR	REPAIR
INSTR.	1. PIEZOMETERS	P-1 through P-5	X		
	2. OBSERVATION WELLS	Various monitoring wells at perimeter of unit.	X		
	3. STAFF GAGE AND RECORDER	None present	X		
	4. WEIRS	None present	X		
	5. INCLINOMETERS	None present	X		
	6. SURVEY MONUMENTS	None present	X		
	7. DRAINS	None present	X		
	8. FREQUENCY OF READINGS	Quarterly	X		
	9. LOCATION OF READINGS	Facility's operating record.	X		

ADDITIONAL COMMENTS: _____

NAME OF DAM: Pond 003

STATE ID #: MO-0001171

INSPECTION DATE: July 15th, 2022

NID ID #: N/A

DOWNSTREAM AREA

AREA INSPECTED	CONDITION	OBSERVATIONS	NO ACTION	MONITOR	REPAIR
D/S AREA	1. ABUTMENT LEAKAGE	None present	X		
	2. FOUNDATION SEEPAGE	None present	X		
	3. SLIDE, SLOUGH, SCARP	None present	X		
	4. WEIRS	None present	X		
	5. DRAINAGE SYSTEM	None present	X		
	6. INSTRUMENTATION	Monitoring wells	X		
	7. VEGETATION	Grass. Woody vegetation between east embankment and Mississippi River	X		
	8. ACCESSIBILITY	Gravel and paved access road along crest. Full time security and fence	X		
9. DOWNSTREAM HAZARD DESCRIPTION	None present	X			
10. DATE OF LAST EAP UPDATE		18-Apr-22			

ADDITIONAL COMMENTS: _____

NAME OF DAM: Pond 003

STATE ID #: MO-0001171

INSPECTION DATE: July 15th, 2022

NID ID #: N/A

PRIMARY SPILLWAY

AREA INSPECTED	CONDITION	OBSERVATIONS	NO ACTION	MONITOR	REPAIR
SPILLWAY	SPILLWAY TYPE	Decant structure	X		
	WEIR TYPE	Concrete stoplogs in decant structure.	X		
	SPILLWAY CONDITION	Fair	X		
	TRAINING WALLS	None present	X		
	SPILLWAY CONTROLS AND CONDITION	None present	X		
	UNUSUAL MOVEMENT	None present	X		
	APPROACH AREA	Fair	X		
	DISCHARGE AREA	Fair	X		
	DEBRIS	None present	X		
	WATER LEVEL AT TIME OF INSPECTION	298.8	X		

ADDITIONAL COMMENTS: _____

NAME OF DAM: Pond 003

STATE ID #: MO-0001171

INSPECTION DATE: July 1th, 2022

NID ID #: N/A

OUTLET WORKS

AREA INSPECTED	CONDITION	OBSERVATIONS	NO ACTION	MONITOR	REPAIR
OUTLET WORKS	TYPE	Outlet unable to be inspected. Downstream submerged in unlined creek.	X		
	INTAKE STRUCTURE	Decant structure with stoplogs	X		
	TRASHRACK	N/A	X		
	PRIMARY CLOSURE	N/A	X		
	SECONDARY CLOSURE	N/A	X		
	CONDUIT	N/A	X		
	OUTLET STRUCTURE/HEADWALL	N/A	X		
	EROSION ALONG TOE OF DAM	N/A	X		
	SEEPAGE/LEAKAGE	N/A	X		
	DEBRIS/BLOCKAGE	N/A	X		
	UNUSUAL MOVEMENT	N/A	X		
	DOWNSTREAM AREA	Regularly mowed grassy vegetation. Creek is riprap lined.	X		
MISCELLANEOUS					

ADDITIONAL COMMENTS: _____

NAME OF DAM: Pond 003

STATE ID #: MO-0001171

INSPECTION DATE: July 15th, 2022

NID ID #: N/A

UNDERLYING HYDRAULIC STRUCTURES/PIPES

AREA INSPECTED	CONDITION	OBSERVATIONS	NO ACTION	MONITOR	REPAIR
UNDERLYING HYDRAULIC STRUCTURES /PIPES	TYPE	Outlet pipe unable to be inspected	X		
	INLET	N/A	X		
	CONDUIT	Outlet pipe unable to be inspected	X		
	OUTLET STRUCTURE/HEADWALL	Fair	X		
	EROSION ALONG STRUCTURE	None present	X		
	SEEPAGE/LEAKAGE	None present	X		
	DEBRIS/BLOCKAGE	None present	X		
	UNUSUAL MOVEMENT	None present	X		
	DOWNSTREAM AREA	None present	X		
	MISCELLANEOUS				

ADDITIONAL COMMENTS: Outlet pipe unable to be inspected. Downstream end of outlet was submerged in unlined creek to Mississippi River

Note: Use additional sheets for additional outlets.