Annual CCR Surface Impoundment PE Inspection

Pond 003 New Madrid Power Plant New Madrid, MO

Associated Electric Cooperative, Inc.

Inspection

Visual Inspection

On January 15, 2021, a visual inspection of the surface impoundment was completed. The visual inspection included both a visual inspection of the CCR impoundment to identify signs of distress or malfunction and a visual inspection of the hydraulic structures for structural integrity. The following subsections and enclosed inspection report describe the conditions observed during the inspection.

Changes in Geometry

There have been no changes to the geometry of the impounding structure since the previous annual inspection.

Instrumentation Readings

Piezometers/monitoring wells are located along the crest of the dikes of Pond 003. The piezometers/groundwater monitoring wells were installed for purposes of monitoring groundwater and are not monitored for structural stability purposes. No readings were taken. No other instrumentation was identified as part of the inspection.

Impounded Water Depth

On the inspection date, the pond water elevation was recorded at 299.3 ft. The concrete stop logs in the decant structure have been set at an approximate elevation of 302 ft. and have not been adjusted.

Storage Capacity

The remaining storage capacity of the impoundment was approximated to be 167 acre-ft. As part of normal operation, ash collected in the pond is periodically disposed of in the Utility Waste Landfill and a very minimal amount of ash accumulates in the pond.

Volumes

The impounded water is approximated to be 48 acre-ft. The impounded CCR volume was approximated to be 1768 acre-ft. As part of normal operation, ash collected in the pond is periodically disposed of in the Utility Waste Landfill and a very minimal amount of ash accumulates in the pond.

Inspection for Structural Weaknesses

The impoundment was visually inspected for any appearances of an actual or potential structural weakness of the CCR unit. The visual inspection did not indicate any deficiencies. Details of this inspection can be found in the enclosed inspection checklist.

Certification

The assessment of the general condition of the surface impoundment is based upon available data and visual observation as required by 40 CFR 257.83 (b) – Inspection Requirements for CCR Surface Impoundments. In reviewing this report, it should be realized that the described condition of the surface impoundment is based on observations of field conditions at the time of inspection. Conditions of surface impoundments depend on numerous internal and external conditions; therefore, it should be noted that the estimates and observations only represent the conditions at the time of inspection.

Signed: Loull Dennis Cex

Print Name: Lowell Dennis Cox

Missouri License Number: 2001004579

Date: 1/22/2021

LOWELL DENNIS COX NUMBER E-2001004579

Dam/Impoundment Evaluation Summary Detail Sheet

1. NID ID:	N/A		4. Inspection Date:	January 15, 2021	
2. Dam Name:	Pond 003		5. Last Insp. Date:	January 6, 2020	
3. Dam Location:	41 St. Jude	Park, Marston, MO	6. Next Inspection:		
7. Inspector:	Dennis Cox	, P. E.			
8. Consultant:	N/A				
9. Hazard Code:		9a. Is Hazard Code Char	ge Requested?:		
10. Insp. Frequency:		11. Overall Physical Con-	dition of Dam:		
12. Spillway Capacity	/ (% SDF)	•			
E1. Design Methodol	ogy:	4	E7. Low-Level Discharg	je Capacity:	4
E2. Level of Maintena	ance:	4	E8. Low-Level Outlet Ph	nysical Condition:	4
E3. Emergency Actio	n Plan:	5	E9. Spillway Design Flo	od Capacity:	N/A
E4. Embankment Sec	epage:	5	E10. Overall Physical C	ondition of the Dam:	5
E5. Embankment Cor	ndition:	5	E11. Estimated Repair (Cost:	N/A
E6. Concrete Conditi	on:	5			

Evaluation Description

E1: DESIGN METHODOLOGY

- Unknown Design no design records available
- 2. No design or post-design analyses
- 3. No analyses, but dam features appear suitable
- Design or post design analysis show dam meets most criteria
- 5. State of the art design design records available & dam meets all criteria

E2: LEVEL OF MAINTENANCE

- 1. Dam in disrepair, no evidence of maintenance, no O&M manual
- 2. Dam in poor level of upkeep, very little maintenance, no O&M manual
- 3. Dam in fair level of upkeep, some maintenance and standard procedures
- 4. Adequate level of maintenance and standard procedures
- 5. Dam well maintained, detailed maintenance plan that is executed

E3: EMERGENCY ACTION PLAN

- 1. No plan or idea of what to do in the event of an emergency
- 2. Some idea but no written plan
- 3. No formal plan but well thought out
- Available written plan that needs updating
- 5. Detailed, updated written plan available and filed with MADCR, annual training

E4: SEEPAGE (Embankments, Foundations, & Abutments)

- 1. Severe piping and/or seepage with no monitoring
- Evidence of monitored piping and seepage
- 3. No piping but uncontrolled seepage
- 4. Minor seepage or high volumes of seepage with filtered collection
- 5. No seepage or minor seepage with filtered collection

E5: EMBANKMENT CONDITION

- 1. Severe erosion and/or large trees
- 2. Significant erosion or significant woody vegetation
- 3. Brush and exposed embankment soils, or moderate erosion
- 4. Unmaintained grass, rodent activity and maintainable erosion
- 5. Well maintained healthy uniform grass cover

E6: CONCRETE CONDITION

- 1. Major cracks, misalignment, discontinuities causing leaks, seepage or stability concerns
- Cracks with misalignment inclusive of transverse cracks with no misalignment but with potential for significant structural degradation
- 3. Significant longitudinal cracking and minor transverse cracking
- 4. Spalling and minor surface cracking
- 5. No apparent deficiencies

E7: LOW-LEVEL OUTLET DISCHARGE CAPACITY

- No low level outlet, no provisions (e.g. pumps, siphons) for emptying pond
- 2. No operable outlet, plans for emptying pond, but no equipment
- Outlet with insufficient drawdown capacity, pumping equipment available
- Operable gate with sufficient drawdown capacity
- 5. Operable gate with capacity greater than necessary

E8: LOW-LEVEL OUTLET PHYSICAL CONDITION

- 1. Outlet inoperative needs replacement, non-existent or inaccessible
- 2. Outlet inoperative needs repair
- 3. Outlet operable but needs repair
- 4. Outlet operable but needs maintenance
- 5. Outlet and operator operable and well maintained

E9: SPILLWAY DESIGN FLOOD CAPACITY

- 1. 0 50% of the SDF or unknown
- 2. 50-90% of the SDF
- 3 90 100% of the SDF
- >100% of the SDF with actions required by caretaker (e.g. open outlet)
- 5. >100% of the SDF with no actions required by caretaker

E10: OVERALL PHYSICAL CONDITION OF DAM

- UNSAFE Major structural, operational, and maintenance deficiencies exist under normal operating conditions
- POOR Significant structural, operation and maintenance deficiencies are clearly recognized under normal loading conditions
- FAIR Significant operational and maintenance deficiencies, no structural deficiencies. Potential deficiencies exist under unusual loading conditions that may realistically occur. Can be used when uncertainties exist as to critical parameters
- SATISFACTORY Minor operational and maintenance deficiencies. Infrequent hydrologic events would probably result In deficiencies.
- 5. GOOD No existing or potential deficiencies recognized. Safe performance is expected under all loading including SDF

E11: ESTIMATED REPAIR COST

Estimation of the total cost to address all identified structural, operational, maintenance deficiencies. Cost shall be developed utilizing standard estimating guides and procedures

Changes/Deviations to Database Information since Last Inspection

l de la companya de		
		· · · · · · · · · · · · · · · · · · ·
l de la companya de		

DAM SAFETY INSPECTION CHECKLIST

NAME OF DAM: Pond 003	STATE ID #: MO-0001171
REGISTERED: (YES/NO) No	NID ID #: N/A
STATE SIZE CLASSIFICATION: <u>N/A</u>	STATE HAZARD CLASSIFICATION: TBD CHANGE IN HAZARD CLASSIFICATION REQUESTED?: (YES/NO) No
<u>DAM LOCATION</u>	<u>INFORMATION</u>
CITY/TOWN: New Madrid	COUNTY/STATE: New Madrid/Missouri
DAM LOCATION: (street address if known) 41 St. Jude Park, Marston, MO	ALTERNATE DAM NAME: N/A
USGS QUAD.: New Madrid, MO-KY	LAT.: 36° 30.4' N LONG.: 89° 33.5' W
DRAINAGE BASIN: <u>N/A</u>	RIVER: Mississippi River
IMPOUNDMENT NAME(S): Unlined Ash Pond (003 Pond)	
GENERAL DAM	<u>INFORMATION</u>
TYPE OF DAM: Earthen Incised and Bermed	OVERALL LENGTH (FT): 9300
PURPOSE OF DAM: Sedimentation and Storage Basin	NORMAL POOL STORAGE (ACRE-FT):
YEAR BUILT: 1972	MAXIMUM POOL STORAGE (ACRE-FT): 1707
STRUCTURAL HEIGHT (FT): 20	EL. NORMAL POOL (FT): 299.6
HYDRAULIC HEIGHT (FT): 8	EL. MAXIMUM POOL (FT): 307.0 (minimum crest elevation)
RESERVOIR SURFACE AREA (ACRES): 110	WINTER DRAWDOWN (FT BELOW NORMAL POOL) 0.0
PUBLIC ROAD ON CREST: No PUBLIC BRIDGE OVER SPILLWA'No	DRAWDOWN VOL. (AC-FT) <u>0.0</u>

NAME OF DAM: Pond 003	STATE ID #:	MO-0001171	
INSPECTION DATE: January 15, 2021	NID ID #:	N/A	
	INSPECTION SUM	<u>MARY</u>	
DATE OF INSPECTION: January 15, 2021	DATE OF PREVI	OUS INSPECTION:	January 6, 2020
TEMPERATURE/WEATHER: Cloudy, 39 Degrees CONSULTANT: N/A BENCHMARK/DATUM: NAVD88	ARMY CORPS (YES/NO PREVIOUS ALT (YES/NO	O) . PHASE I:	If YES, date If YES, date
OVERALL PHYSICAL CONDITION OF DAM: SPILLWAY CAPACITY:	DATE OF LAST	REHABILITATION:	<u>N/A</u>
EL. POOL DURING INSP.: 299.3 ft	EL. TAILWATER	DURING INSP.:	297.3 ft
<u>NAME</u> <u>T</u>	ONS PRESENT AT II ITLE/POSITION visor - Coal Plant En	REPRES	SENTING

NAME OF DAM: Pond 003	STATE ID #: MO-0001171
VNER: ORGANIZATION NAME/TITLE Dennis Cox - Senior Plant Eng. STREET P.O. Box 156 New Madrid, MO 63869 PHONE EMERGENCY PH. # FAX EMAIL OWNER TYPE Private ILLWAY LENGTH (FT) N/A WILLWAY TYPE Decant Structure PEOF OUTLETS One PEOF OUTLETS One PEOF OUTLETS One Decant Associated Electric Cooperative, I Dennis Cox - Senior Plant Eng. P.O. Box 156 New Madrid, MO 63869 P.O. Box 156 New Madrid, MO 63869 Private N/A Private ILLWAY SPILLWAY TYPE Decant Structure ILLWAY LENGTH (FT) N/A IMBER OF OUTLETS One PEOF OUTLETS One Decant AINAGE AREA (SQ MI) 0.17 S DAM BEEN BREACHED OR TERTOPPED? (YES/NO): No	NID ID #: N/A
NAME/TITLE STREET P.O. Box 156 TOWN, STATE, ZIP PHONE EMERGENCY PH. # FAX EMAIL	CARETAKER: ORGANIZATION NAME/TITLE STREET TOWN, STATE, ZIP PHONE EMERGENCY PH. # FAX EMAIL Associated Electric Cooperative, Inc. Dennis Cox - Senior Plant Eng. P.O. Box 156 New Madrid, MO 63869 New Madrid, MO 63869
PRIMARY SPILLWAY TYPE Decant Structure	
SPILLWAY LENGTH (FT) N/A	SPILLWAY CAPACITY (CFS) N/A
AUXILIARY SPILLWAY TYPE <u>N/A</u>	AUX. SPILLWAY CAPACITY (CFS) N/A
NUMBER OF OUTLETS One	OUTLET(S) CAPACITY (CFS) Unknown
TYPE OF OUTLETS One Decant	TOTAL DISCHARGE CAPACITY (CFS) Unknown
DRAINAGE AREA (SQ MI) 0.17	SPILLWAY DESIGN FLOOD (PERIOD/CFS) Unknown
HAS DAM BEEN BREACHED OR OVERTOPPED? (YES/NO): No	IF YES, PROVIDE DATE(S)
FISH LADDER (LIST TYPE IF PRESENT) Unknown	
DOES CREST SUPPORT PUBLIC ROAD? (YES/NO) No	IF YES, ROAD NAME:
PUBLIC BRIDGE WITHIN 50' OF DAM? (YES/NO): No	IF YES, ROAD/BRIDGE NAME: MHD BRIDGE NO. (IF APPLICABLE)

NAME OF DA	AM: Pond 003	STATE ID #: <u>MO-0001171</u>	_		
INSPECTION	DATE: January 15, 2021	NID ID #: <u>N/A</u>	-		
		EMBANKMENT (CREST)			
AREA INSPECTED	CONDITION	OBSERVATIONS	NO ACTION	MONITOR	REPAIR
	1. SURFACE TYPE				
	2. SURFACE CRACKING	None observed	X		
1	3. SINKHOLES, ANIMAL BURROWS	None observed	X		
5.	4. VERTICAL ALIGNMENT (DEPRESSIONS		X		
	5. HORIZONTAL ALIGNMENT	Alignment has not shifted or moved	X		
	6. RUTS AND/OR PUDDLES	None observed	X		
	7. VEGETATION (PRESENCE/CONDITION)		X	<u> </u>	<u> </u>
	8. ABUTMENT CONTACT	None observed	X	Щ.	$ldsymbol{f eta}$
			igsquare	Ь—	<u> </u>
			igsquare	Ь—	<u> </u>
			$\perp \perp \mid$	Ь—	<u> </u>
			$\vdash \vdash$	├─	├
			+	├─	\vdash
			+	\vdash	\vdash
 					
ADDITIONA	L COMMENTS:				

NAME OF D	AM: Pond 003	STATE ID #: <u>MO-0001171</u>	_		
INSPECTIO	N DATE: January 15, 2021	NID ID #: N/A	-		
		EMBANKMENT (D/S SLOPE)			
AREA INSPECTED	CONDITION	OBSERVATIONS	NO ACTION	MONITOR	REPAIR
	1. WET AREAS (NO FLOW)	None observed	X		
i	2. SEEPAGE	None observed	X		
i	3. SLIDE, SLOUGH, SCARP	None observed	X		
D/S	4. EMBABUTMENT CONTACT	N/A			
SLOPE 5.	5. SINKHOLE/ANIMAL BURROWS	None observed	X		
	6. EROSION	None observed	X		
	7. UNUSUAL MOVEMENT	None observed	X		
ĺ	8. VEGETATION (PRESENCE/CONDITION)	Slopes are mowed grass.	X		
i			\sqcup		
1			\sqcup	لـــــا	—
			$\vdash \vdash$		
1			\vdash		—
			\vdash		—
			\vdash		—
 	<u> </u>				
ADDITIONA	AL COMMENTS:				
1					
1					

NAME OF DA	M: Pond 003	STATE ID #: MO-0001171			
	DATE: January 15, 2021	NID ID #: N/A	_		
		EMBANKMENT (U/S SLOPE)			
AREA INSPECTED	CONDITION	OBSERVATIONS	NO ACTION	MONITOR	REPAIR
U/S SLOPE	1. SLIDE, SLOUGH, SCARP 2. SLOPE PROTECTION TYPE AND COND. 3. SINKHOLE/ANIMAL BURROWS 4. EMBABUTMENT CONTACT 5. EROSION 6. UNUSUAL MOVEMENT 7. VEGETATION (PRESENCE/CONDITION)	None observed	X X X X X X		
ADDITIONAL		evation equal to the embankment in the Northern portion of the Unlined Ash Pond. ras covered by ash and not visible for inspection.			

NAME OF DA	AM: Pond 003	STATE ID #: MO-0001171	_		
INSPECTION	DATE: January 15, 2021	NID ID #: N/A	_		
		INSTRUMENTATION			
AREA INSPECTED	CONDITION	OBSERVATIONS	NO ACTION	MONITOR	REPAIR
	1. PIEZOMETERS	P-1 through P-3	X		
	2. OBSERVATION WELLS	None present	X		
	3. STAFF GAGE AND RECORDER	None present	X		
5.]	4. WEIRS	None present	X		
	5. INCLINOMETERS	None present	X		
	6. SURVEY MONUMENTS	None present	X		
	7. DRAINS	None present	X		
	8. FREQUENCY OF READINGS	No measurements are taken	X		
	9. LOCATION OF READINGS	N/A	X		
			↓		
				<u> </u>	
ADDITIONA [®]	L COMMENTS:				

	AM: Pond 003 N DATE: January 15, 2021	STATE ID #: MO-0001171 NID ID #: N/A			
		DOWNSTREAM AREA			
AREA INSPECTED	CONDITION	OBSERVATIONS	NO ACTION	MONITOR	REPAIR
	1. ABUTMENT LEAKAGE	None Present	X		
	2. FOUNDATION SEEPAGE	None Present	X		
	3. SLIDE, SLOUGH, SCARP	None Present	X		\Box
AREA 5.	4. WEIRS	None Present	X		$oxed{oxed}$
	5. DRAINAGE SYSTEM	None Present	X		
	6. INSTRUMENTATION	None Present	X	\perp	$oxed{oxed}$
6. II 7. V	7. VEGETATION	Grass less than 6"	X		
	8. ACCESSIBILITY	Gravel access road along crest. Full time security and fence	X		\vdash
		 	-+	+	+
			_	\vdash	t
	9. DOWNSTREAM HAZARD DESCRIPTION	1		+	t
				\vdash	
	10. DATE OF LAST EAP UPDATE				T
ADDITIONA	L COMMENTS:				

NAME OF DA	AM: Pond 003	STATE ID #: MO-0001171			
INSPECTION	DATE: January 15, 2021	NID ID #: <u>N/A</u>			
		PRIMARY SPILLWAY			
AREA INSPECTED	CONDITION	OBSERVATIONS	NO ACTION	MONITOR	REPAIR
	SPILLWAY TYPE	Decant structure	X		
	WEIR TYPE	Concrete stoplogs in decant structure	X		
	SPILLWAY CONDITION	Fair	X		
S	TRAINING WALLS	None present	X		
	SPILLWAY CONTROLS AND CONDITION	X			
	UNUSUAL MOVEMENT	None present	X		
	APPROACH AREA	Fair	X		
	DISCHARGE AREA	Fair	X		
	DEBRIS	None present	X		
	WATER LEVEL AT TIME OF INSPECTION	299.3'	X		<u> </u>
					<u> </u>
					_
				-	
ADDITIONA	L COMMENTS:				

NAME OF D	AM: Pond 003	STATE ID #: MO-0001171			
INSPECTION	N DATE: January 15, 2021	NID ID #: N/A			
		OUTLET WORKS			
	CONDITION	OBSERVATIONS	NO ACTION	MONITOR	REPAIR
	ТҮРЕ	Outlet unable to be inspected.	X		
i	INTAKE STRUCTURE	Decant structure with stoplogs	X		
i	TRASHRACK	N/A	X		
AREA INSPECTED TYF INT TRA OUTLET PRII WORKS SEC CON OUT ERC SEE DEF UNIT DOV	PRIMARY CLOSURE	N/A	X		
	SECONDARY CLOSURE	N/A	X		
	CONDUIT	N/A	X		
	OUTLET STRUCTURE/HEADWALL	Fair	X		
	EROSION ALONG TOE OF DAM	None	X		
	SEEPAGE/LEAKAGE	None	X		
	DEBRIS/BLOCKAGE	None	X		
	UNUSUAL MOVEMENT	None	X		
İ	DOWNSTREAM AREA	Regularly mowed.	X	lacksquare	igspace
İ	MISCELLANEOUS			—	\vdash
1	MISCELLANEOUS	- -		\vdash	\vdash
		, <u> </u>			<u>—</u>
ADDITIONA [*]	L COMMENTS:				
1					
i					
1					_
4					

NAME OF DAM	I: Pond 003	STATE ID #: <u>MO-0001171</u>			
INSPECTION D	ATE: January 15, 2021	NID ID #: N/A			
	UNDERLY	YING HYDRAULIC STRUCTURES/PIPES			
AREA INSPECTED	CONDITION	OBSERVATIONS	NO ACTION	MONITOR	REPAIR
	ТҮРЕ	Not observed			
	INLET				
UNDERLYING					
HYDRAULIC	OUTLET STRUCTURE/HEADWALL	Fair			
	EROSION ALONG STRUCTURE	None present			
/PIPES	SEEPAGE/LEAKAGE DEBRIS/BLOCKAGE	None present			
	UNUSUAL MOVEMENT	None present			
	DOWNSTREAM AREA				
	DO WIND INDINITION				
	MISCELLANEOUS				
ADDITIONAL C	COMMENTS:				

Note: Use additional sheets for additional outlets.